



IDAHO DEPARTMENT OF
HEALTH & WELFARE

BRAD LITTLE – Governor
DAVE JEPPESEN – Director

TAMARA PRISOCK—ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
TOM MOSS, LSW – PROGRAM SUPERVISOR
RESIDENTIAL ASSISTED LIVING PROGRAM
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 364-1962
E-mail: ralf@dhw.idaho.gov

July 9, 2019

Randi Knefel, Administrator
Edgewood Spring Creek Eagle, LLC
PO Box 13238
Grand Forks, ND 58208

License #: RC-1007

Dear Randi Knefel:

On June 6, 2019, a Fire Life Safety Survey was conducted at Edgewood Spring Creek Eagle, LLC. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

«POCEORAcceptanceBlock»

This office is accepting your evidence of resolution

Should you have questions, please contact Linda Chaney, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626, option 3.

Sincerely,

A handwritten signature in blue ink that reads "Jamie Simpson". The signature is fluid and cursive.

Linda Chaney
Health Facility Surveyor
Facility Fire Safety & Construction Program

LC/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

BRAD LITTLE – Governor
DAVE JEPPESEN – Director

TAMARA PRISOCK—ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
TOM MOSS, LSW – PROGRAM SUPERVISOR
RESIDENTIAL ASSISTED LIVING PROGRAM
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 364-1962
E-mail: ralf@dhw.idaho.gov

July 31, 2019

Randi Knefel, Administrator
Edgewood Spring Creek Eagle, LLC
PO Box 13238
Grand Forks, ND 58208

License #: RC-1007

Dear Randi Knefel:

On June 6, 2019, a Fire Life Safety Survey was conducted at Edgewood Spring Creek Eagle, LLC. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

«POCEORAcceptanceBlock»

This office is accepting your evidence of resolution.

Should you have questions, please contact Linda Chaney, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626, option 3.

Sincerely,

A handwritten signature in blue ink that reads "Jamie Simpson". The signature is written in a cursive, flowing style.

Linda Chaney
Health Facility Surveyor
Facility Fire Safety & Construction Program

LC/lj

NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Edgewood Spring Creek Eagle, LLC	RC-1007	653 North Eagle Road	208-938-1590
Administrator	City	Zip Code	Survey Date
Randi Knefel	Eagle	83616	06/06/2019
Survey Team Leader	Survey Type		Response Due
Chaney, Linda	Fire Life Safety and Sanitation Licensure		07/08/2019

Item #	Rule (16.03.22)	Description
1	.250.10. Plumbing.	Water temperature at resident room sink was 123 degrees.
2	.250.13.I. Resident Sleeping Rooms.	Closet door had been removed in resident room #17 with no variance for its removal on file.
3	.405.03. Medical Gases.	Five unsecured oxygen cylinders in the closet of resident room 11a. (Corrected by Administrator 6/6/19)
4	.415.04.a. Fire Alarm Smoke Detection System Service and Testing.	No documentation for a 5 year sensitivity test of the smoke detectors. Maintenance Supervisor verified the system is not addressable.