

## NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Ashley Manor - Arlington	RC-1077	3123 South Arlington Avenue	208-459-9009
Administrator	City	Zip Code	Survey Date
Megan Thomason	Caldwell	83605	01/30/2025
Survey Team Leader	Survey Type		Response Due
Hoover, Shaun	fire life safety and sanitation licensure		03/01/2025

Item #	Rule (16.03.22)	Description
1	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	1.) ***REPEAT. Previously cited on 11/07/2022*** The facility was unable to produce documentation for the testing of emergency lighting 30-seconds monthly and 90-minute annually. (NFPA 101, 7.9.3.1.1). 2.) The facility was unable to produce documentation to show monthly visual inspections of the wet suppression system gauges and secured control valves were completed. (NFPA 25, 13.2.7.1).
2	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	***THREE-PEAT. Previously cited on 12/09/2021 and 11/07/2022*** Emergency egress and relocation drills are required not less than six (6) times a year on a bi-monthly basis with at least two (2) drills conducted at night when the residents are sleeping. The facility failed to produce drills conducted on a bi-monthly basis, or at night when the the residents were sleeping.