

NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Terraces of Boise, The	RC-1115	5301 East Warm Springs Ave	208-336-5550
Administrator	City	Zip Code	Survey Date
Bobbi Moore	Boise	83716	01/07/2025
Survey Team Leader	Survey Type		Response Due
Wilson, Jeremy	fire life safety and sanitation licensure		02/06/2025

Item #	Rule (16.03.22)	Description
1	.405.03. Medical Gases.	Facility failed to maintain proper storage of oxygen cylinders in accordance with NFPA 99, Chapter 11, Section 11.6.2.3 (11). During facility tour it was identified in room # 308, approximately 6 A-sized oxygen cylinders sitting directly on the carpeted floor. All freestanding oxygen cylinders shall be properly stored in a rack or cart.