

NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Diamond Peak of Pocatello	RC-1139	5685 South Bannock Highway	208-239-0480
Administrator	City	Zip Code	Survey Date
Wendy Webb	Pocatello	83204	02/08/2023
Survey Team Leader	Survey Type		Response Due
Chaney, Linda	fire life safety and sanitation licensure		03/10/2023

Item #	Rule (16.03.22)	Description
1	.405.02.c. Prohibited Applications.	During the facility tour, observation of installed electrical systems revealed a coffee pot was plugged into a Relocatable Power Tap (RPT) in both the office and the dining room. This is a prohibited use for a RPT.
2	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	The facility did not maintain compliance with the 2018 edition of NFPA 101, Life Safety Code, Chapter 33, Existing Residential Board and Care Occupancies, Small Facilities as evidenced by the following: 1.) Fire extinguishers in the facility were not visually inspected in January of 2023.(NFPA 10, 7.2.2)