

## NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Avista Senior Living Twin Falls	RC-1297	1800 Harrison St N	208-733-7511
Administrator	City	Zip Code	Survey Date
Tamra Watson	Twin Falls	83301	08/29/2024
Survey Team Leader	Survey Type		Response Due
Wilson, Jeremy	fire life safety and sanitation licensure		09/28/2024

Item #	Rule (16.03.22)	Description
1	.405.02.a. Prohibited Applications.	During facility tour Room #133 was observed using a relocatable power tap (RPT) to supply power to an oxygen concentrator. Using a RPT to power medical devices is a prohibited use and application.
2	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	Based on review of provided fire drill documents, the facility failed to conduct the two (2) required fire/evac drills to be held during night when residents are typically sleeping. Fire drills must be conducted not less than six (6) times a year on a bimonthly basis, with not less than two (2) conducted during the night when residents are sleeping. Records must be maintained on file at the facility and contain a description, date, and time of the drill, response of the personnel and residents, problems encountered, and recommendations for improvement.