

## NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Joyce's Orchard Residential Care Home	RC-148	615 Cedar Avenue	208-746-5695
Administrator	City	Zip Code	Survey Date
Joy Cook	Lewiston	83501	10/27/2022
Survey Team Leader	Survey Type		Response Due
Burbank, Sam	fire life safety and sanitation licensure		11/26/2022

Item #	Rule (16.03.22)	Description
1	.403. FIRE AND LIFE SAFETY STANDARDS FOR EXISTING BUILDINGS LICENSED FOR THREE THROUGH SIXTEEN RESIDENTS.	No documentation for 30 second monthly and 90 minute annual testing of emergency lighting in accordance with NFPA 101, Chapter 7, Section 7.9
2	.405.04. Fuel-Fired Heating.	No documented annual fuel-fired heating inspection
3	.410. REQUIREMENTS FOR EMERGENCY ACTIONS AND FIRE DRILLS.	No documented emergency egress and relocation drills documented on site for review. All drills shall be conducted in accordance with NFPA 101, Chapter 33, Section 33.7