



IDAHO DEPARTMENT OF  
HEALTH & WELFARE

BRAD LITTLE – Governor  
ALEX J. ADAMS- DIRECTOR

LAURA STUTE-- ADMINISTRATOR  
DIVISION OF LICENSING & CERTIFICATION  
NATE ELKINS., Chief  
BUREAU OF FACILITY STANDARDS  
3232 Elder Street  
P.O. Box 83720  
Boise, ID 83720-0009  
PHONE 208-334-6626  
FAX 208-364-1888

April 4, 2019

Joy Cook, Administrator  
Pleasant Valley Shelter Home  
1917 17th Avenue  
Lewiston, ID 83501

Dear Mr./Ms. Cook

On March 28, 2019, a Fire Life Safety Survey was conducted at Pleasant Valley Shelter Home. The facility was found to be providing a safe environment for its residents.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference, on March 28, 2019. The facility must correct non-core issue deficiencies within thirty (30) calendar days of the exit conference. Please ensure the deficiencies are corrected for all residents, staff and situations, not just those sampled during the survey, and that a plan for monitoring the situation to ensure continued compliance is implemented. The team leader will contact you in 7 to 10 days to schedule a post-survey conference. The purpose of this conference is to help you understand how compliance will be determined on the follow-up survey, so that you can make certain your corrections are adequate to avoid repeat deficiencies and maintain ongoing compliance.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

Sam Burbank, Supervisor  
Facility Fire Safety & Construction Program

SB/df

## NON-CORE ISSUES

| Facility                     | License #                                 | Physical Address | Phone Number |
|------------------------------|-------------------------------------------|------------------|--------------|
| Pleasant Valley Shelter Home | RC-226                                    | 1911 17th Avenue | 208-743-0026 |
| Administrator                | City                                      | Zip Code         | Survey Date  |
| Joy Cook                     | Lewiston                                  | 83501            | 03/28/2019   |
| Survey Team Leader           | Survey Type                               |                  | Response Due |
| Burbank, Sam                 | Fire Life Safety and Sanitation Licensure |                  | 04/28/2019   |

| Item # | Rule (16.03.22)                                                 | Description                                                                                                                                                                                                         |
|--------|-----------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1      | .405.01. Medical Gases.                                         | Electrical panels shall be kept free of storage allowing 36" clearance in accordance with NFPA 70, Section 110. Basement electrical panel blocked by a chair and misc. storage.                                     |
| 2      | .415.04. Fire Alarm Smoke Detection System Service and Testing. | No record of annual fire alarm inspection on site. No record for five-year sensitivity testing on site.                                                                                                             |
| 3      | .410.02. Fire Drills.                                           | Fire drills shall be conducted one per shift per quarter: Fire drills missing for noc shift (10 o'clock pm to 6 o'clock am) for second, third and fourth quarter. Documented fire drills were performed at 8:00 pm. |