

| | | | |
|--|--|---|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 225434 | (X2) MULTIPLE CONSTRUCTION A. Building B. Wing | (X3) DATE SURVEY COMPLETED 04/23/2025 |
| NAME OF PROVIDER OR SUPPLIER Boston Home, Inc (the) | | STREET ADDRESS, CITY, STATE, ZIP CODE 2049 Dorchester Avenue Boston, MA 02124 | |

For information on the nursing home's plan to correct this deficiency, please contact the nursing home or the state survey agency.

| | |
|---|---|
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (Each deficiency must be preceded by full regulatory or LSC identifying information) |
| Level of Harm - Unknown Residents Affected - Unknown | No health deficiencies found |

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER
REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE