



MAINE DEPARTMENT OF HEALTH AND HUMAN SERVICES LICENSING AND CERTIFICATION ASSISTED HOUSING

STATEMENT OF DEFICIENCIES & PLAN OF CORRECTION Biennial License Survey	Date Completed: 09/12/2024
--	-------------------------------

Name of Facility: Always One Administrator: Brian Q. Noble Level I Residential Care Facility. Census: 3 Total Capacity: 3 License Number: RCA 1331	Address: 172 Grove Street Bangor, ME 04401
--	--

Summary Statement of Deficiencies	Plan of Correction	Completion Date
-----------------------------------	--------------------	-----------------

<p>Always One, a Level III Residential Care Facility, is <i>not in</i> compliance with the Regulations Governing the Licensing and Functioning of Assisted Housing Programs: Level III Residential Care Facilities and Infection Prevention and Control Part of 10-144, Chapter 113.</p> <p>The following was not met:</p> <p>14. Safety Standards 14.3 Drills or rehearsals. 14.3.2 Facilities with 3 or more beds shall conduct drills or rehearsals of the emergency steps to be taken at irregular times of the day, at least 6 (six) times per year spaced throughout the year. Two of the six drills must be conducted while residents are asleep. [Class II]</p> <p>This has not been met as evidenced by:</p> <p>Based on record review and interview the facility failed to conduct two sleeping drills within a one-year period.</p> <p>Finding:</p> <p>On 9/9/204 Fire Drill records were reviewed. The facility conducted one fire drill when residents were asleep on 8/15/2023 and a second fire drill when residents were asleep was conducted on 9/1/2024, not within a 12-month timeframe for two required sleep drills.</p> <p>This finding was confirmed with the Program Director at the exit interview on 9/9/2024.</p>	<p>Click or tap here to enter text.</p>	<p>Click or tap here to enter text.</p>
---	---	---