

Missouri Department of Health and Senior Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 26902	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 03/28/2024
--	--	--	---

NAME OF PROVIDER OR SUPPLIER BARATHAVEN ALZHEIMER'S SPECIAL CARE CENTE	STREET ADDRESS, CITY, STATE, ZIP CODE 1030 BARATHAVEN DRIVE DARDENNE PRAIRIE, MO 63368
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

A3214	<p>19 CSR 30-86.032(13) Electrical Wiring, Maintained, Inspected</p> <p>In facilities that are constructed or have plans approved after July 1, 2005, electrical wiring shall be installed and maintained in accordance with the requirements of the National Electrical Code, 1999 edition, National Fire Protection Association, Inc., incorporated by reference, in this rule and available by mail at One Batterymarch Park, Quincy, MA 02269, and local codes. This rule does not incorporate any subsequent amendments or additions to the materials incorporated by reference. Facilities built between September 28, 1979 and July 1, 2005 shall be maintained in accordance with the requirements of the National Electrical Code, which was in effect at the time of the original plan approval and local codes. This rule does not incorporate any subsequent amendments or additions. In facilities built prior to September 28, 1979, electrical wiring shall be maintained in good repair and shall not present a safety hazard. All facilities shall have wiring inspected every two (2) years by a qualified electrician. II/III</p> <p>This regulation is not met as evidenced by: Class III</p> <p>Based on record review and interview the facility failed to properly maintain the buildings electrical wiring. The facility census was 46. This deficiency affects 46 of 46 residents.</p> <p>A records review showed no documentation provided for the two year electrical wire certification.</p> <p>During an interview on 3-28-2024 at 1:30 P.M. the maintenance director said he would contact the electrical company to see when the last one was</p>	A3214		
-------	--	-------	--	--

Missouri Department of Health and Senior Services
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

6899

7PL811

If continuation sheet 1 of 2

Missouri Department of Health and Senior Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 26902	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/28/2024
--	--	---	---

NAME OF PROVIDER OR SUPPLIER BARATHAVEN ALZHEIMER'S SPECIAL CARE CENTE	STREET ADDRESS, CITY, STATE, ZIP CODE 1030 BARATHAVEN DRIVE DARDENNE PRAIRIE, MO 63368
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A3214	Continued From page 1 completed.	A3214		

