

CORE ISSUES

Facility	License #	Physical Address	Phone Number
Echoview Assisted Living, LLC	31525	1373 Whitefish Stage	406-314-2233
Administrator	City	Zip Code	Survey Date
Cameron Stewart	Kalispell	59901	03/12/2019
Survey Team Leader	Survey Type		Response Due
Dennison, Lisa	Renewal Inspection		03/22/2019

Item #	Rule ()	Description
1	37.106.2865-12 PHYSICAL PLANT	Surveyor measurement of the facility water temperature supplied to hand washing, bathing and showering showed that temperature was over 140 degrees Fahrenheit, thus exceeding the maximum temperature of 120 degrees Fahrenheit.