



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Foundation House	Provider Number	001917
Address	32290 1st ,	Approval Status	Approved
City, State, Zip	Federal Way, WA 98003	Facility Type	Residential Care

On 01/18/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 114474

Here's a complaint of broken water pipes

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? N/A
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? Yes

On January 18, 2024 DSFM Christian entered Brookdale Foundation House in regards to complaint # 114474. The complaint was regarding a busted sprinkler pipe.

I spoke with the maintenance person who stated during the cold weather they had a sprinkler pipe burst in resident room 117. The resident was removed from the room while they wait for repairs to be conducted. At this time they are currently waiting for the contractor to schedule a time to come out. The facility is conducting a fire watch at this time.


When repairs have been made and the system is back up and running the facility will need to contact me and send over their fire watch forms.


No violations observed at this time.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

 Brian Thompson
Print Name and Title

 Director of Maintenance

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature