



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Stephen's Place	Provider Number	2414
Address	501 SE ELLSWORTH RD ,	Approval Status	Approved
City, State, Zip	Vancouver, WA 986645148	Facility Type	Residential Care

On 01/17/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Heather Bartholomew, Exec. Dir
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966


Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name	Stephen's Place	Provider Number	2414
Address	501 SE ELLSWORTH RD ,	Approval Status	Disapproved
City, State, Zip	Vancouver, WA 986645148	Facility Type	Residential Care

On 12/12/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Inspection and Maintenance

<p>Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.</p> <p>(IFC 705.2 2021)</p>	<p>Facility shall provide an annual fire door inspection report</p>
---	---

2 Duct and Air Transfer Openings - Maintaining Protection

<p>Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.</p> <p>(IFC 706.1 2018)</p>	<p>Facility shall provide 4 year fire damper inspection report</p>
--	--

3 Testing and Maintenance

<p>Sprinkler systems shall be tested and maintained in accordance with Section 901.</p> <p>(IFC 903.5 2021)</p>	<p>Facility shall provide 5 year FDC hydrostatic test report Facility shall provide 3 year dry sprinkler full trip test</p>
---	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name Stephen's Place	Provider Number 2414
Address 501 SE ELLSWORTH RD ,	Approval Status Disapproved
City, State, Zip Vancouver, WA 986645148	Facility Type Residential Care

On 12/12/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Operational Inspection and Testing

<p>Emergency power systems, including all appurtenant components, shall be inspected and tested under load in accordance with NFPA 110 and NFPA 111.</p> <p>Exception: Where the emergency power system is used for standby power or peak load shaving, such use shall be recorded and shall be allowed to be substituted for scheduled testing of the generator set, provided that appropriate records are maintained.</p> <p>(IFC 1203.5 2021)</p>	<p>Facility shall provide annual generator inspection report</p>
--	--

Next inspection scheduled on or after: 01/11/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Heather Bartholomew
 Signature

Heather Bartholomew, Exec. Director
 Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
 1823 BAKER WAY
 Kelso WA 98626
 (360) 852-0966

Nicholas Wolden
 Signature

*New 2024/25 leaf posted
 12/12/24 - posted
 12/12/24 - posted
 12/12/24 - posted
 12/12/24 - posted*