



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Hillside Assisted Living	Provider Number	2693
Address	112 KENNEBECK AVE N,	Approval Status	Approved
City, State, Zip	Kent, WA	Facility Type	Residential Care

On 9/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Jenifer Futch
Signature

Jenifer Futch, Executive Director

Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392

D.R.
Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Hillside Assisted Living

Business Name	Stafford Suites Kent	Provider Number	2693
Address	112 KENNEBECK AVE N,	Approval Status	Disapproved
City, State, Zip	Kent, WA	Facility Type	Residential Care

On 9/9/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Administration

	On 9/9/25 an announced Fire and Life Safety Code Inspection was conducted at Stafford Suites Kent now known as Hillside Assisted Living by a representative of the Washing State Patrol, State Fire Marshal's Office to determine compliance with all applicable codes.
--	---

2 Extension Cords

<p>Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors..</p> <p>(IFC 603.6 2021)</p>	<p>Extension cord used as permanent wiring in room 104.</p> <p>This was corrected while on site.</p>
--	--

3 Penetrations - Maintaining Protection

<p>Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions.</p> <p>(IFC 703.1 2021)</p>	<p>Penetrations in fire-resistance-rated construction were found in the following places:</p> <ol style="list-style-type: none"> 1. Staff break room above door 2. Basement by holiday storage
--	--

4 Emergency Lighting Equipment Inspection and Testing

<p>Emergency lighting shall be maintained in accordance with Section 1008 and shall be inspected and tested in accordance with Sections 1031.10.1 and 1031.10.2.</p> <p>(IFC 1032.10 2021)</p>	<p>During testing, emergency light across from room 213 failed to operate on backup power.</p>
--	--



**Washington State Patrol
Fire Protection Bureau**
Phone: (360) 596-3900

Business Name	Stafford Suites Kent	Provider Number	2693
Address	112 KENNEBECK AVE N,	Approval Status	Disapproved
City, State, Zip	Kent, WA	Facility Type	Residential Care

On 9/9/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

5 Reliability

<p>Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the building area served by the means of egress is occupied. An exit or exit passageway shall not be used for any purpose that interferes with a means of egress.</p> <p>(IFC 1032.2 2021)</p>	<p>There was a table and chair blocking the means of egress in the dining area.</p> <p>This was corrected while on site.</p>
--	--

Next inspection scheduled on or after: 10/9/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Kenifer Fitch, Executive Director
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392


Signature